

State of California
Department of Health Services
Water Treatment Device
Certificate Number

03 - 1579

Date Issued: June 25, 2003
Date Revised: February 9, 2004

<u>Trademark/Model Designation</u>	<u>Replacement Elements</u>	<u>Capacity</u>
Multi-Pure Plus 1100SB	MPPT	1100 gal
Multi-Pure Plus 1100SC	MPPT	1100 gal
Multi-Pure Plus 1100SI	MPPT	1100 gal
Multi-Pure Plus 1600SB	MPPT	1600 gal
Multi-Pure Plus 1600SC	MPPT	1600 gal
Multi-Pure CB1100SB	CBT	1100 gal
Multi-Pure CB1100SC	CBT	1100 gal
Multi-Pure CB1100SI	CBT	1100 gal
Multi-Pure CB1600SB	CBT	1600 gal
Multi-Pure CB1600SC	CBT	1600 gal

Manufacturer: Multi-Pure

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

Microbiological Contaminants and Turbidity

Cysts
Turbidity

Inorganic/Radiological Contaminants

Asbestos
Lead
Mercury

Organic Contaminants

Chlordane
MTBE
PCB
Toxaphene
VOCs

Alachlor
Bromodichloromethane¹
Carbon Tetrachloride
2,4-D
o-Dichlorobenzene
1,2-Dichloroethane
cis-1,2-Dichloroethylene
Dinoseb
Ethylbenzene
Hexachlorocyclopentadiene
Methoxychlor
Styrene
1,1,2,2-Tetrachloroethane
1,1,1-Trichloroethane
m-Xylene

Atrazine
Bromoform¹
Chlorobenzene
DBCP
p-Dichlorobenzene
trans-1,2-Dichloroethylene
1,2-Dichloropropane
EDB
Heptachlor
Hexachlorobutadiene
Pentachlorophenol
2,4,5-TP (Silvex)
Toluene
1,1,2-Trichloroethane
o-Xylene

Benzene
Carbofuran
Chloroform¹
Dibromodichloromethane¹
1,1-Dichloroethane
1,1-Dichloroethylene
cis-1,3-Dichloropropylene
Endrin
Heptachlor Epoxide
Lindane
Simazine
Tetrachloroethylene
1,2,4-Trichlorobenzene
Trichloroethylene
p-Xylene

¹Trihalomethanes

Rated Service Flow: 1.0 gpm

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.